



Approval Number: 1503521
Test Report: MAT/LAB 624H/1

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

18th March 2015

PC Chanda & Co. PVT Ltd.
Ravi Auto House,
103 Park Street,
6th Floor,
Kolkata 700016,
India

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS - FACTORY APPLIED PIPE & FITTINGS COATINGS.

5030

EDELCLRX FN 221. Factory applied, pale cream coloured, rubber based resin coating. Apply as per manufacturer's instructions reference PC 221, dated April 05, 2010. Cure for 7 days@30°C. For use with water up to 23°C. This material is only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

APPROVAL NUMBER: 1503521

APPROVAL HOLDER: PC CHANDA & CO. PVT LTD.

The Scheme reserves the right to review approval.
Approval 1503521 is valid between March 2015 and March 2020

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme