

Approval Number: 1410532  
Test Report: MAT/LAB 623H



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

4<sup>th</sup> November 2014

PC Chanda & Co. PVT Ltd.  
Ravi Auto House,  
103 Park Street,  
6th Floor,  
Kolkata 700016,  
India

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**BITUMINOUS BASED PRODUCTS - SMALL SURFACE AREA CONTACT ONLY**

**5021**

PCBIT III Bituminous Coating. Factory applied, black coloured bitumen coating. Apply as per manufacturer's instructions. Cure for 7 days@30°C. For use with water up to 23°C. Petroleum or asphaltic bitumen, NOT coal tar bitumen. Materials listed in this section are not approved for use for contact with water that is required to be wholesome on large water retaining structures such as lining of pipes, cisterns or water storage tanks.

**APPROVAL NUMBER: 1410532**

**APPROVAL HOLDER: PC CHANDA & CO. PVT LTD.**

The Scheme reserves the right to review approval.  
Approval 1410532 is valid between October 2014 and October 2019

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in blue ink, appearing to read 'Jason Furnival'. The signature is stylized and cursive.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme